

## Caséta Load Controls

The Caséta family of dimmers, switches, and fan controls can be controlled directly and remotely when paired with Pico remote controls providing a system that delivers convenience and ease of installation.

Caséta dimmers, switches, and fan controls use Lutron patented Clear Connect RF Technology which enables wireless communication with Pico remote controls, Caséta motion sensors, and the Lutron Smart Hub and Smart Hub PRO (formerly Smart Bridge and Smart Bridge PRO).

### Features

- Works with Pico remote control
- Works with Caséta motion sensor
- Works with the Lutron App (via a Smart Hub or Smart Hub PRO)<sup>1</sup>
- Lutron patented Clear Connect RF Technology works through walls and floors
- Includes Front Accessible Service Switch (FASS) for safe lamp replacement
- Works with Lutron Radio Powr Savr occupancy and vacancy sensors in standalone applications (sensors do not work with Smart Hub or Smart Hub PRO)




Figure 1:  
Original Smart Switches




Figure 2:  
Original Smart Dimmers




Figure 3: Original  
ELV+ Smart Dimmers




Figure 4: Caséta Plug-In  
Lamp Dimmers




Figure 5: Original  
Smart Fan Controls




Figure 6: Diva  
Smart Dimmers




Figure 7: Claro  
Smart Switches




Figure 8: Claro Smart  
Accessory Switches

Note: Certain models or load types will require a neutral connection (see Load Type and Capacity sections).

<sup>1</sup> The Lutron App is required for setup and usage with the Smart Hub and Smart Hub PRO. The Lutron App is compatible with iOS® devices version 8.0 or later and Android™ devices 4.0 or later.

### SPECIFICATION SUBMITTAL

<p><b>Job Name:</b></p> <p><b>Job Number:</b></p>	<p><b>Model Numbers:</b></p>
--	------------------------------

## Specifications

### Regulatory Approvals

- cULus Listed
- NOM Certified
- FCC Approved. Complies with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules
- Industry Canada Certified
- IFTEL Certified
- NEMA 410: PD (-5ANS, -6ANS, -5WS, -10NXD, -5NE), DVRF (-6L, -5NS)

### Power

Operating voltage:

- 120 V~ 50/60 Hz: PD (-3PCL, -6WCL, -10NXD, -6ANS, -5ANS, -5NE, -FSQN), DVRF (-6L, -5NS, -AS)
- 120/277 V~ 50/60 Hz: -5WS-DV

### Key Design Features

- Tested to withstand electrostatic discharge without damage or memory loss, in accordance with IEC 61000-4-2.
- Tested to withstand surge voltages without damage or loss of operation, in accordance with IEEE C62.41-1991 Recommended Practice on Surge Voltages in Low-Voltage AC Power Circuits.
- Load controls always operate locally and do not require system control.
- Power failure memory: should power be interrupted, the control will return to its previously set level prior to the interruption when power is restored.
- PD-5WS-DV, PD-5ANS, PD-6ANS, PD-10NXD, DVRF-5NS, and DVRF-6L use conventional 3-way wiring.
- DVRF-6L and DVRF-5NS can also be wired with an accessory switch, DVRF-AS.
- Uses Lutron Claro wallplates or designer-style wallplates from other manufacturers. Wallplates are sold separately.
- Lutron Claro wallplates snap on with no visible means of attachment.
- Requires a 1-gang U.S. wallbox. 3½ in (89 mm) depth recommended, 2¼ in (57 mm) depth minimum<sup>1</sup>.

<sup>1</sup> PD-FSQN requires 2½ in (63½ mm) minimum depth.

### Key Design Features (continued)

- PD- models use green status LED(s) to indicate load status.
- DVRF-6L uses a white soft glow light bar and the DVRF-5NS uses a white status LED to indicate load status.
- PD-FSQN provides 4 quiet fan speeds plus OFF for a single ceiling fan.

### System Communications and Capacity

- Caséta switches, dimmers, and fan controls communicate with Pico remote controls, Caséta motion sensors, and the Lutron Smart Hub/Smart Hub PRO through Radio Frequency (RF).
- The Caséta switches, dimmers, and fan controls must be located within 60 ft (18 m) line-of-sight or 30 ft (9 m) through walls of a Lutron Smart Hub, Smart Hub PRO, or Caséta Repeater.
- The Caséta switches, dimmers, and fan controls must be located within 60 ft (18 m) line-of-sight or 30 ft (9 m) through walls of Pico remote controls or Caséta motion sensors (with no Smart Hub installed).

### Device limits

- Pico remote controls and Caséta motion sensors: up to 10 devices (total) may be paired to each Caséta switch/dimmer (with no Smart Hub installed).
- Smart Hub or Smart Hub PRO system: up to 75 total wireless devices (Caséta dimmers/switches, Pico remote controls, Caséta motion sensors, and shades) are supported per system. Smart Hub or Smart Hub PRO counts as one device. The Caséta repeater counts as one device.

### Environment

- Ambient operating temperature: 32 °F to 104 °F (0 °C to 40 °C), 0% to 90% humidity, non-condensing. Indoor use only.
- PD-5WS-DV, PD-5ANS, PD-6ANS, PD-10NXD, DVRF-5NS, and DVRF-6L can be used with a mechanical switch in 3-way applications.

<p><b>Job Name:</b></p> <p><b>Job Number:</b></p>	<p><b>Model Numbers:</b></p>
--	------------------------------

## Features

Original Smart Models	2-wire Switch PD-5WS-DV	Neutral Switch PD-5ANS, PD-6ANS	Dimmer PD-6WCL	PRO Dimmer PD-10NXD	ELV+ Dimmer PD-5NE	Plug-In Dimmer PD-3PCL	Fan Control PD-FSQN
<b>Figure # (from page 1)</b>	<b>1</b>	<b>1</b>	<b>2</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>
Simple two-wire installation (no neutral wire required)	√		√	√ <sup>1</sup>			
Capable of dimming loads			√	√	√	√	
Preset (user defined favorite level)					√		√
Works with Hi-lume 1% 2-Wire LED Drivers (forward-phase only)	√	√	√	√	√		
Works with Power Interfaces (PHPM and GRX-TVI)				√	√		
Works with Power Interfaces (PHPM-SW)		√					
No wiring required						√	
Controls speed of a single ceiling fan							√

Diva and Claro Smart Models	Diva Smart Dimmer DVRF-6L	Claro Smart Switch DVRF-5NS	Claro Smart Accessory Switch DVRF-AS
<b>Figure # (from page 1)</b>	<b>6</b>	<b>7</b>	<b>8</b>
Simple two-wire installation (no neutral wire required)	√		√
Capable of dimming loads	√		
Preset (user defined favorite level)	√		
Works with Hi-lume 1% 2-Wire LED Drivers (forward-phase only)	√	√	
Works with Power Interfaces (PHPM-SW)		√	

<sup>1</sup> In some low-wattage applications the PD-10NXD will require a neutral wire connection.

<b>Job Name:</b>	<b>Model Numbers:</b>
<b>Job Number:</b>	

### Load Type and Capacity - Switches and Fan Control

Model Number	Description	Voltage	Load Type	Minimum Load	Maximum Load <sup>3</sup>		
					Not Ganged	End of Gang	Middle of Gang
PD-5WS-DV <sup>1</sup>	Two-wire switch	120 V~	Incandescent/ Halogen	25 W	600 W	450 W	350 W
		277 V~	Incandescent/ Halogen	25 W	1350 W	1100 W	800 W
		120 V~	MLV	25 W	600 VA/475 W	450 VA/350 W	350 VA/275 W
		277 V~	MLV	25 W	1350 VA/1075 W	1100 VA/875 W	800 VA/625 W
		120 V~	General Purpose Fan	0.4 A	3 A	3 A	3 A
		120/277 V~	LED	Use LUT-MLC <sup>2</sup>	5 A	4 A	3 A
		120/277 V~	Fluorescent	Use LUT-MLC <sup>2</sup>	5 A	4 A	3 A
		120 V~	ELV	Use LUT-MLC <sup>2</sup>	600 W	450 W	350 W
		277 V~	ELV	Use LUT-MLC <sup>2</sup>	1350 W	1100 W	800 W
PD-5ANS DVRF-5NS	Neutral-wire switch (neutral connection required)	120 V~	Incandescent/ Halogen	10 W	600 W	600 W	600 W
			MLV	10 W	600 VA	600 VA	600 VA
			Fan	0.1 A	3 A	3 A	3 A
			LED	1 bulb	5 A	5 A	5 A
			Fluorescent	1 ballast	5 A	5 A	5 A
			ELV	10 W	600 W	600 W	600 W
			PHPM-SW	1 interface	2 interfaces	2 interfaces	2 interfaces
PD-6ANS PD-6ANS-XX-C	Neutral-wire switch (neutral connection required)	120 V~	Incandescent/ Halogen	10 W	720 W	720 W	600 W
			MLV	10 W	720 VA	720 VA	600 VA
			Fan	0.1 A	3.6 A	3.6 A	3.6 A
			LED	1 bulb	6 A	6 A	5 A
			Fluorescent	1 ballast	6 A	6 A	5 A
			ELV	10 W	720 W	720 W	600 W
			PHPM-SW	1 interface	3 interfaces	3 interfaces	3 interfaces
PD-FSQN <sup>4</sup>	Fan speed control (neutral connection required)	120 V~	Single Ceiling Fan (permanent split-capacitor motor)	0.1 A	1.5 A	1.5 A	1.5 A

<sup>1</sup> No neutral wire required.

<sup>2</sup> To ensure proper operation of the switch with LED, fluorescent, and ELV loads, a LUT-MLC (included) may be required, especially at lower wattages. If the status LED on the switch is flashing or solid red in color, a LUT-MLC must be installed. To guarantee best performance, installing a LUT-MLC with these load types regardless of wattage is recommended. Rarely, some load types may still flicker or glow in the off state even with the LUT-MLC installed, in which case a different load may be required or more than one LUT-MLC is required.

<sup>3</sup> See "Ganging and Derating" section.

<sup>4</sup> Not for use with fans that have integrated fan speed and/or light control modules, DC motor fans, fans with remote controls, bathroom or kitchen exhaust type fans.

<b>Job Name:</b>	<b>Model Numbers:</b>
<b>Job Number:</b>	

## Load Type and Capacity - Dimmers

Model Number	Description	Voltage	Load Type	Minimum Load	Maximum Load			
					Not Ganged	End of Gang	Middle of Gang	
PD-10NXD PD-10NXD-XX-C <sup>8</sup>	Dimmer PRO (neutral connection required for certain load types) <sup>4</sup>	120 V~	Incandescent/Halogen	10 W with neutral (25 W without neutral)	1000 W	800 W	600 W	
			MLV Halogen	10 W	1000 VA	800 VA	600 VA	
			MLV LED	See Application Note #559				
			LED (120 V~ Rated) <sup>3</sup>	1 bulb <sup>3</sup>	250 W	250 W	250 W	
			Hi-lume 1% 2-Wire LED drivers	1 driver	13 drivers	13 drivers	13 drivers	
			Dimmable Ballasts <sup>5</sup>	1 ballast	1000 VA	800 VA	600 VA	
			PHPM-PA/3F and GRX-TVI <sup>4</sup>	1 interface	3 interfaces	3 interfaces	3 interfaces	
PD-3PCL <sup>1,9</sup> PD-3PCL-WH-C <sup>1,8,9</sup>	Plug-In Lamp Dimmer	120 V~	Incandescent/Halogen	10 W	300 W	N/A	N/A	
			LED (120 V~ Rated) <sup>3</sup>	1 bulb <sup>3</sup>	100 W	N/A	N/A	
PD-5NE PD-5NE-XX-C <sup>8</sup>	Phase Selectable Dimmer (neutral connection required)	120 V~	Incandescent/Halogen	10 W	500 W	400 W	300 W	
			LED (120 V~ Rated) <sup>3,6,7</sup>	1 bulb <sup>3</sup>	250 W	250 W	250 W	
			MLV Halogen <sup>2,6,7</sup>	10 W	400 VA	400 VA	400 VA	
			ELV Halogen	10 W	500 W	400 W	300 W	
			Hi-lume 1% 2-Wire LED drivers <sup>6,7</sup>	1 driver	20 drivers	20 drivers	20 drivers	
			Dimmable Ballasts <sup>5,6,7</sup>	1 ballast	400 VA	400 VA	400 VA	
			PHPM-PA/3F and GRX-TVI <sup>6,7</sup>	1 interface	3 interfaces	3 interfaces	3 interfaces	
			ELV LED	See Application Note #559				
			MLV LED <sup>6,7</sup>	See Application Note #559				
PD-6WCL PD-6WCL-XX-C <sup>8</sup> DVRF-6L	Dimmer	120 V~	Incandescent/Halogen	25 W	600 W	500 W	400 W	
			LED (120 V~ Rated) <sup>3</sup>	1 bulb <sup>3</sup>	150 W	150 W	150 W	

<sup>1</sup> Cannot be ganged.

<sup>2</sup> Need to change load type to MLV. See [www.casetawireless.com/change\\_phase](http://www.casetawireless.com/change_phase)

<sup>3</sup> See bulb list at [www.lutron.com/led](http://www.lutron.com/led)

<sup>4</sup> For PD-10NXD, a neutral connection is required for MLV loads, LED drivers, dimmable ballasts, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).

<sup>5</sup> Compatible dimmable ballasts include Tu-Wire, Mark 10<sup>+</sup>, and PowerSense<sup>+</sup>.

<sup>6</sup> These loads are best operated using a forward-phase control. Consult <https://www.casetawireless.com/support> to ensure the appropriate phase for bulb models used.

<sup>7</sup> SSL7 compliant when in forward-phase.

<sup>8</sup> Canadian packaged product.


<sup>9</sup> Available in WH only.

<b>Job Name:</b>	<b>Model Numbers:</b>
<b>Job Number:</b>	

## Ganging and Derating


When ganging with other switches/dimmers in the same wallbox, derating is required. See “Load Type and Capacity” charts.

### Original Smart Models



Note: Fin removal is not required for PD-5WS-DV, as it ships without fins.

### Diva and Claro Smart Models




Note: DVRF- models don't have fins but derating may still be required. See “Load Type and Capacity” charts.

<p>Job Name:</p> <p>Job Number:</p>	<p>Model Numbers:</p>
--	-----------------------


# Operation

## Original Smart Models

### Switches




### Dimmers




### FASS – Front Accessible Service Switch

**Important Notice:** To service load, remove power by pulling out the FASS as far as possible. To restore power after servicing load, push the FASS back in completely.

### Plug-In Dimmer



### Fan Control




Job Name:	Model Numbers:
Job Number:	


Operation (continued)

Diva and Claro Smart Models

Dimmer




Switch



**FASS – Front Accessible Service Switch**


**Important Notice:** To service load, remove power by pulling out the FASS as far as possible. To restore power after servicing load, push the FASS back in completely.

Accessory Switch



Job Name:	Model Numbers:
Job Number:	

# Mounting



**Note:** Fin removal is not required for PD-5WS, DVRF-6L, DVRF-5NS, and DVRF-AS. They all ship without fins.


<p>Job Name:</p> <p>Job Number:</p>	<p>Model Numbers:</p>
--	-----------------------

## Dimensions


### Original Smart Models

#### Switches and Dimmers

Front View




Side View




#### Fan Control

Front View




Side View




#### Plug-In Dimmer

Front View



Side View




Job Name:	Model Numbers:
Job Number:	

Dimensions (continued)


Diva and Claro Smart Models

Dimmer

Front View




Side View




Switch

Front View




Side View




Accessory Switch

Front View



Side View



<p>Job Name:</p> <p>Job Number:</p>	<p>Model Numbers:</p>
--	-----------------------

## Wiring Diagram Table of Contents

### Switches (PD-5WS-DV, PD-5ANS, PD-6ANS, DVRF-5NS)

[Single Pole Installation \(load is controlled from 1 location\)](#)..... 13

#### 3-way Installation (load is controlled from 2 locations)

[Option 1: With a mechanical switch](#) ..... 14

[Option 2: With a Pico remote controls](#)..... 16

[Option 3: With an Accessory Switch](#) ..... 17

#### Multi-location Installation (load is controlled from 3 or more locations)

[Option 1: With Pico remote controls](#)..... 18

[Option 2: With Accessory Switches](#) ..... 19

### Dimmers (PD-10NXD, PD-6WCL, PD-5NE, DVRF-6L)

[Single Pole Installation \(load is controlled from 1 location\)](#)..... 20

#### 3-way Installation (load is controlled from 2 locations)

[Option 1: With a mechanical switch](#) ..... 21

[Option 2: With a Pico remote controls](#)..... 23

[Option 3: With an Accessory Switch](#) ..... 24

#### Multi-location Installation (load is controlled from 3 or more locations)

[Option 1: With Pico remote controls](#)..... 25

[Option 2: With Accessory Switches](#) ..... 26

### Installation With Power Interfaces and LED Drivers - Neutral Required

[Option 1: PHPM](#) ..... 27

[Option 2: GRX-TVI](#) ..... 28

[Option 3: Hi-lume 1% 2-wire LED Drivers](#) ..... 28

### Fan Control

[Single Pole](#)..... 29

#### 3-way Installation (load is controlled from 2 locations)


[Option 1: With Pico remote controls](#)..... 29

<p>Job Name:</p> <p>Job Number:</p>	<p>Model Numbers:</p>
--	-----------------------


# Wiring Diagrams - Switches

## Single Pole Installation (load is controlled from 1 location)

### PD-5WS-DV



### PD-5ANS, PD-6ANS, DVRF-5NS



<sup>1</sup> When using controls without a mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

<sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.

<sup>3</sup> The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.


(continued on next page...)

Job Name:	Model Numbers:
Job Number:	


### Wiring Diagrams - Switches *(continued)* 3-Way Installation (load is controlled from 2 locations)

Option 1: With mechanical switch

#### PD-5WS-DV (Load-side)



#### PD-5WS-DV (Line-side)



<sup>1</sup> Location of Caséta switch and mechanical switch may be reversed.

<sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.

(continued on next page...)


Job Name:	Model Numbers:
Job Number:	

### Wiring Diagrams - Switches *(continued)*


#### 3-Way Installation (load is controlled from 2 locations) *(continued)*

Option 1: With mechanical switch *(continued)*

##### PD-5ANS, PD-6ANS, DVRF-5NS (Load-side)



##### PD-5ANS, PD-6ANS, DVRF-5NS (Line-side)



<sup>1</sup> Location of Caséta switch and mechanical switch may be reversed.

<sup>2</sup> The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

Job Name:	Model Numbers:
Job Number:	


## Wiring Diagrams - Switches *(continued)*

### 3-Way Installation (load is controlled from 2 locations) *(continued)*


Option 2: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)

#### PD-5WS-DV



#### PD-5ANS, PD-6ANS, DVRF-5NS



<sup>1</sup> When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

<sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.

<sup>3</sup> The mechanical switch will need to be removed so the Pico remote control can be installed.

<sup>4</sup> The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

(continued on next page...)

Job Name:	Model Numbers:
Job Number:	


## Wiring Diagrams - Switches *(continued)*

### 3-Way Installation (load is controlled from 2 locations) *(continued)*


Option 3: With an accessory switch

DVRF-5NS and Smart Accessory Switch (DVRF-AS)

#### DVRF-5NS (Line Side)



#### DVRF-5NS (Load Side)



Job Name:	Model Numbers:
Job Number:	


## Wiring Diagrams - Switches *(continued)*

### Multi-location Installation (load is controlled from 3 or more locations)


Option 1: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)

#### PD-5WS-DV



#### PD-5ANS, PD-6ANS, DVRF-5NS



<sup>1</sup> When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

<sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.

<sup>3</sup> The mechanical switch will need to be removed so the Pico remote control can be installed.

<sup>4</sup> The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

Job Name:	Model Numbers:
Job Number:	


## Wiring Diagrams - Switches *(continued)*

### Multi-location Installation (load is controlled from 3 or more locations) *(continued)*


Option 2: With accessory switches

DVRF-5NS and Smart Accessory Switch (DVRF-AS)<sup>1</sup>

#### DVRF-5NS (Line Side)




#### DVRF-5NS (Load Side)



#### DVRF-5NS (In the Middle)

**Note:** Main switch can go in any location.




<sup>1</sup> Up to ten (10) accessory switches may be connected to the switch. Total blue wire connection wire length may be up to 150 ft (45 m).

<p><b>Job Name:</b></p>	<p><b>Model Numbers:</b></p>
<p><b>Job Number:</b></p>	


## Wiring Diagrams - Dimmers

### Single Pole Installation (load is controlled from 1 location)


#### PD-10NXD or PD-5NE



#### PD-6WCL



#### DVRF-6L



<sup>1</sup> When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

<sup>2</sup> Location of Caséta dimmer PRO and mechanical switch may be reversed.

<sup>3</sup> For PD-10NXD only, neutral connection optional except for MLV loads, LED drivers, and power modules (PHPM-PA, PHPM-3F, and GRX-TV).

<sup>4</sup> For PD-5NE, neutral is required.

<sup>5</sup> Blue wire is only present on the PD-10NXD and DVRL-6L models.


<b>Job Name:</b>	<b>Model Numbers:</b>
<b>Job Number:</b>	

### Wiring Diagrams - Dimmers (continued)


#### 3-Way Installation (load is controlled from 2 locations)

Option 1: With mechanical switch

##### PD-10NXD, PD-5NE (Load-side)



##### PD-10NXD, PD-5NE (Line-side)




Job Name:	Model Numbers:
Job Number:	


**Wiring Diagrams - Dimmers (continued)**  
**3-Way Installation (load is controlled from 2 locations) (continued)**

Option 1: With mechanical switch (continued)

**DVRF-6L (Load-side)**



**DVRF-6L (Line-side)**



Job Name:	Model Numbers:
Job Number:	


## Wiring Diagrams - Dimmers (continued)

### 3-Way Installation (load is controlled from 2 locations) (continued)


Option 2: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)

#### PD-10NXD, PD-5NE



#### DVRF-6L



<sup>1</sup> When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

<sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.

<sup>3</sup> The mechanical switch will need to be removed so the Pico remote control can be installed.

<sup>4</sup> When using a Pico in a 3-way installation with a dimmer the Black and Red wires are reversible.

Job Name:	Model Numbers:
Job Number:	


## Wiring Diagrams - Dimmers *(continued)*

### 3-Way Installation (load is controlled from 2 locations) *(continued)*


Option 3: With an accessory switch

DVRF-6L and Smart Accessory Switch (DVRF-AS)<sup>1</sup>

#### DVRF-6L (Line Side)



#### DVRF-6L (Load Side)



<sup>1</sup> When using an accessory switch in a multi-location installation with a dimmer the Black and Red wires are reversible.

Job Name:	Model Numbers:
Job Number:	


### Wiring Diagrams - Dimmers (continued)

#### Multi-Location Installation (load is controlled from 3 or more locations)


Option 1: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)


#### PD-10NXD or PD-5NE



#### PD-6WCL



#### DVRF-6L



- 1 When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.
- 2 Location of Caséta dimmer PRO and mechanical switch may be reversed.
- 3 For PD-10NXD only, neutral connection optional except for MLV loads, LED drivers, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).
- 4 For PD-5NE, neutral is required.
- 5 Blue wire is only present on the PD-10NXD and DVRF-6L models.
- 6 When using a Pico in a 3-way installation with a dimmer the Black and Red wires are reversible.

<b>Job Name:</b>	<b>Model Numbers:</b>
<b>Job Number:</b>	


## Wiring Diagrams - Dimmers (continued)

### Multi-location Installation (load is controlled from 3 or more locations) (continued)


Option 2: With accessory switches

DVRF-6L and Smart Accessory Switches (DVRF-AS)<sup>1,2</sup>

#### DVRF-6L (Line Side)




#### DVRF-6L (Load Side)



#### DVRF-6L (In the Middle)

**Note:** Main switch can go in any location.



<sup>1</sup> Up to ten (10) accessory switches may be connected to the dimmer. Total blue wire connection wire length may be up to 150 ft (45 m).

<sup>2</sup> When using an accessory switch in a multi-location installation with a dimmer, the Black and Red wires are reversible.


Job Name:	Model Numbers:
Job Number:	

# Wiring Diagrams - Dimmers *(continued)*

## Installation With Power Interfaces and LED Drivers - Neutral Required

Option 1: PHPM<sup>1</sup>

PD-10NXD or PD-5NE



<sup>1</sup> See Lutron P/Ns 369356 and 369355 for additional wiring diagrams.


Job Name:	Model Numbers:
Job Number:	

### Wiring Diagrams - Dimmers (continued)

#### Installation With Power Interfaces and LED Drivers - Neutral Required (continued)


Option 2: GRX-TVI<sup>1</sup>

PD-10NXD or PD-5NE



Option 3: Hi-lume 1% 2-wire LED Drivers

PD-10NXD or PD-5NE



**Note:** For more information on Hi-lume 1% 2-wire LED drivers, see [www.lutron.com](http://www.lutron.com)

<sup>1</sup> See Lutron P/N 369247 for additional wiring diagrams.


<sup>2</sup> Blue wire is only present on the PD-10NXD model.

Job Name:	Model Numbers:
Job Number:	

# Wiring Diagrams - Fan Controls

## Single Pole Installation (load is controlled from 1 location)

PD-FSQN




## 3-Way Installation (load is controlled from 2 locations)

Option 1: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)

PD-FSQN



<sup>1</sup> The mechanical switch will need to be removed so the Pico remote control can be installed.

Job Name:	Model Numbers:
Job Number:	

## Colors and Finishes

### Gloss Finishes<sup>1</sup>



White  
WH



Black  
BL



Ivory  
IV



Light Almond  
LA



Gray<sup>2</sup>  
GR



Brown<sup>2</sup>  
BR

Due to printing limitations, colors and finishes shown cannot be guaranteed to perfectly match actual product colors.

<sup>1</sup> DVRF- models initially available in WH only.

<sup>2</sup> Only available for DVRF-5NS, DVRF-6L, and DVRF-AS.

The Lutron logo, Lutron, Caséta, Diva, Pico, Clear Connect, Claro, Hi-lume, FASS, Radio Powr Savr, and Tu-Wire are trademarks or registered trademarks of Lutron Electronics Co., Inc. in the US and/or other countries.

All product names, logos, and brands are property of their respective owners.

<b>Job Name:</b>	<b>Model Numbers:</b>
<b>Job Number:</b>	